



Schmucker, Paul, Nohr and Associates

2100 North Sanborn Blvd — PO Box 398

Mitchell SD 57301-0398

Phone (605) 996-7761

Wats (800) 952-3598

FAX (605) 996-0015

www.spn-assoc.com

February 13, 2012

**RE: WATER DISTRIBUTION IMPROVEMENTS
GREGORY, SOUTH DAKOTA
SPN #13574**

BID LETTING: February 16, 2012 @ 2:00 PM

ADDENDUM NUMBER 1

The following modifications are to be made to the specifications and plans for the project to assist the bidders in the preparation of bids.

1. SECTION 02226 - BORED ROAD CROSSINGS, PART 2, PARAGRAPH 2.01 shall be replaced with the following:

2.01 CASING PIPE

Steel casing pipe shall conform to ANSI Specification B36.10 and shall have a minimum yield strength of 35,000 psi and a minimum thickness of 0.25 inches.

2. SECTION 02666 - WATER SERVICE PIPING, FITTINGS AND VALVES, PART 2, PARAGRAPH 2.02 C: Add the following to Paragraph C:

AY McDonald Model 3891 brass saddle is approved.



All other items of the specifications remain unchanged.



Camden A Hofer

Camden A. Hofer, P.E., Project Engineer
Schmucker, Paul, Nohr & Associates

The undersigned hereby acknowledges receipt of Addendum Number 1 to the specifications and plans for the **WATER DISTRIBUTION IMPROVEMENTS PROJECT**.

FIRM NAME _____

BY _____

TITLE _____

DATE _____

ATTACH THIS SIGNED ADDENDUM NO. 1 TO THE BID FORM WHEN SUBMITTING.